



I Mina'trentai Siette Na Liheslaturan Guahan

Thirty-Seventh Guam Legislature

Guam Congress Building

163 W Chalan Santo Papa, Hagatna, Guam 96910

Procurement Office

Email: procurement@guamlegislature.org

Website: www.guamlegislature.org



Invitation for Bid

GL-03-24 – Removal/Install of 90-ton Chiller

May 21, 2024

Questions & Concerns from JWS Refrigeration & Air Conditioning, Ltd. received on May 20, 2024

Specification in question:

“Provide a Voltage Regulator for the new Chiller unit to keep the voltage stable. Existing supply is 480 V., 3 phase and 60 hertz.”

1. Please clarify if you are requiring a stand-alone (separate piece of equipment) installed before power terminated at chiller? This equipment is for the stabilization of the power supply before it is sent to Chiller.

Response: Yes.

2. Or a Voltage Monitor, accessory added within chiller control panel that will detect surges or drops and terminate the power supply, Installed after power terminates at chiller.

Response: No.

Joseph R. San Agustin
Executive Director

Acknowledgement

Received by: _____

Date: _____

Company: _____

Please print copy. Email to: procurement@guamlegislature.org